

Aktualizácia 2015 - úplné znenie

Tabuľka č. 7 - Návrh transformačných staníc

UPC	FPB	Funkčné využitie územia	merná jednotka		NO	VO	NO	VO
			bytová a ubytov. Jednotka	podlaž. plocha v m ²	r. 2030	r. 2045	r. 2030	r. 2045
1	2	3	4	5	Pp v kW	Pp v kW	TS/výkon (kVA)	TS/výkon (kVA)
1	2	3	4	5	9	10	11	12
1 – Bystričany								
1	1.1	OÚ / IBV	35		138,60	-		
	1.1	OV / RÚ		1 863	74,52	-		
	1.2	OÚ / IBV	10		49,50	-		
	1.3	OÚ / IBV	26		102,96		1x630	
	1.4	OÚ / IBV	19		75,24			
	1.5	OÚ / IBV	19		75,24			
	1.18	RÚ / INT		5 805	185,76	-		
	1.19	OÚ / IBV	8		42,24	-		
				Σ	744,06			
	1.6	VÚ / PRV		5 069	202,76	-		
	1.15	V-PO		5 702	182,46	-	1x630	
	1.23	OÚ / IBV	9		52,47			
	1.24	OÚ / IBV	9		52,47	-		
				Σ	490,16			
	1.7	VÚ / PDTZ		5 530	221,20		1x360	
	1.8	VÚ / PRV		1 498	59,92	-	exist.	
	1.9	VÚ / PRV		66 960	1 607,04	-	3x630	
	1.10	VÚ / PRV		156 845	3 764,28	-	4x1000	
	1.12	RÚ / INT		30 931	742,34		1x630	
	1.20	VÚ / POV		5 587	178,78	-	1x360	
	1.13	RÚ / INT		8 395	268,64		1x400	
	1.14A	RÚ / INT		4 464	142,85	-	1x360	
	1.14B	RÚ / INT		7 200		230,40		-
				Σ		373,25		
	1.17	OÚ / IBV	5		30,80		exist.	
	1.11	RÚ / INT		6 394	255,76	-	1x630	
1.21	RÚ / INT		5 724	183,17				
			Σ	438,93				
1.22	RÚ / EXT		0	-	0,00	-	-	
2 – Chalmová								
2	2.1	RÚ / INT		6 048	241,92			
	1.16	RÚ / INT		3 701	148,04	-	1x630	
	2.2	OÚ / IBV	7		39,27			
				Σ	429,23			
	2.3	RÚ / INT		2 722	108,88		exist.	
	2.4	RÚ / INT		3 758	150,32			
	2.5	RÚ / INT		8 035	321,40			
	2.6	RÚ / INT		7 225	289,00			
	2.7	VÚ/PDTZ		0	0,00	-	2x630	
	2.8	VOD.NÁDRŽ		0	0,00			
	2.9A	OÚ / INT		4 159	133,09		-	
	2.9B	OÚ / INT		4 159		133,09	-	
				Σ	893,81			
2.10	RÚ / EXT		0	-	0,00			
3 – Vieska								
3	3.1	OÚ / IBV	10		49,50			
	3.2	OÚ / IBV	4		14,52			
	3.3	VÚ / PRV		4 234	169,36		1x360	
	3.4	VÚ / PRV		1 296	51,84			
	3.5	POH		0	-			
	3.6	VÚ / VSÚ*		864	51,84			
	3.7	RÚ / EXT		0	-	0,00		
			Σ	337,06				

Poznámka : legendu skratiek - viď tab. č.1,3,5